

表14 耐震診断結果の一覧

X 方向		加力方向 正		構造耐震判定指標 $I_{so} = E_s \cdot Z \cdot G_0 \cdot U_0 = 0.60$						診断次数第2次診断						
		地域指標 $Z=1.00$		地盤指標 $G_0=1.00$		用途指標 $U_0=1.00$		経年指標 $T=1.00$								
階	階数補正	適用式	$F'$ ( $F_3$ )	$C_1 + \sum \alpha$ $C_1$	$F_2$	$C_2$	$F_1$	$C_1$	$E_0$	$S_D$	$I_s$	$C_{TU} \cdot S_D$	$C_{T0}$	第2種柱本数	採用	
3F	0.67	(5)式	0.80	0.988	-	-	-	-	0.527	1.000	0.527	0.659	0.300	0		
			1.00	1.335	-	-	-	-	0.890		0.890	0.300	0	○		
			1.50	0.627	-	-	-	-	0.626		0.626	0.418	0.300	2		
			1.75	0.366	-	-	-	-	0.427		0.427	0.244	0.300	2		
			2.00	0.244	-	-	-	-	0.327		0.327	0.163	0.300	2		
		(4)式	1.50	0.627	-	-	1.000	0.762	0.807		0.807	0.418	0.300	2		
			1.75	0.366	-	-	1.000	1.023	0.805		0.805	0.244	0.300	2		
			2.00	0.244	-	-	1.000	1.135	0.825		0.825	0.163	0.300	2		
			0.80	0.600	-	-	-	-	0.384		1.000	0.384	0.480	0.300	0	
			1.00	0.675	-	-	-	-	0.540			0.540	0.540	0.300	0	○
1.50	0.140	-	-	-	-	0.168	0.168	0.112	0.300	5						
1.75	0.104	-	-	-	-	0.145	0.145	0.083	0.300	5						
2.00	0.072	-	-	-	-	0.115	0.115	0.058	0.300	6						
(4)式	2.25	0.016	-	-	-	-	0.030	0.030	0.013	0.300		8				
	1.50	0.140	-	-	1.000	0.567	0.484	0.484	0.112	0.300		5				
	1.75	0.104	-	-	1.000	0.597	0.499	0.499	0.083	0.300		5				
	2.00	0.072	-	-	1.000	0.623	0.512	0.512	0.058	0.300		6				
	2.25	0.016	-	-	1.000	0.664	0.531	0.531	0.013	0.300		8				
1F	1.000	(5)式	0.80	0.668	-	-	-	-	0.535	1.000	0.535	0.668	0.300	0	○	
			1.00	0.300	-	-	-	-	0.300		0.300	0.300	0			
			1.20	0.009	-	-	-	-	0.011		0.011	0.009	0.300	14		
		1.40	0.002	-	-	-	-	0.003	0.003		0.002	0.300	15			
		(4)式	1.20	0.009	-	-	1.000	0.291	0.291		0.291	0.009	0.300	14		
			1.40	0.002	-	-	1.000	0.298	0.298		0.298	0.002	0.300	15		
診断者コメント																

表14 耐震診断結果の一覧

X 方向		加力方向 負		構造耐震判定指標 $I_{so} = E_s \cdot Z \cdot G_0 \cdot U_0 = 0.60$						診断次数第2次診断									
		地域指標 $Z = 1.00$		地盤指標 $G_0 = 1.00$		用途指標 $U_0 = 1.00$		経年指標 $T = 1.00$											
階	階数補正	適用式	$F'$ ( $F_3$ )	$C_1 + \sum \alpha$ $C_1$	$F_2$	$C_2$	$F_1$	$C_1$	$E_0$	$S_D$	$I_s$	$C_{TU} \cdot S_D$	$C_{T0}$	第2種 柱本数	採用				
3F	0.67	(5)式	0.80	1.042	-	-	-	-	0.556	1.000	0.556	0.695	0.300	0	○				
			1.00	1.204	-	-	-	-	0.803		0.803	0.803	0.300	0					
			1.20	0.682	-	-	-	-	0.546		0.546	0.455	0.300	3					
			1.50	0.640	-	-	-	-	0.641		0.641	0.427	0.300	3					
			1.75	0.426	-	-	-	-	0.497		0.497	0.284	0.300	3					
			2.00	0.271	-	-	-	-	0.361		0.361	0.181	0.300	3					
			2.25	0.021	-	-	-	-	0.031		0.031	0.014	0.300	7					
		(4)式	1.20	0.682	-	-	1.000	0.573	0.667		0.667	0.667	0.455	0.300	3				
			1.50	0.640	-	-	1.000	0.624	0.764		0.764	0.764	0.427	0.300	3				
			1.75	0.426	-	-	1.000	0.840	0.748		0.748	0.748	0.284	0.300	3				
			2.00	0.271	-	-	1.000	0.984	0.749		0.749	0.749	0.181	0.300	3				
			2.25	0.021	-	-	1.000	1.188	0.793		0.793	0.793	0.014	0.300	7				
			診断者コメント																